

Top Energy & Demand Saving Opportunities: Retail

Category	Action Item	Potential Low-Cost/ No Cost	Potential Cost Effective Retrofits or Upgrades at Replacement	Potential Cost Effective New Construction Concepts
Envelope	Overhang over storefront window			✓
	Reflective roof		✓	✓
Lighting	For high bay retail, use high output fluorescent instead of HID		✓	✓
	T-8 fluorescent instead of T-12		✓	✓
HVAC	High-efficiency rooftop A/C, EER-13		✓	✓
	Natural gas heating instead of electric resistance		✓	✓
	Indirect-Direct-Supplemental cooling for systems 100+ tons in size		✓	✓
	Evaporative pre-cooling for rooftop A/C 50 tons+ in size		✓	✓
	Variable air volume		✓	✓
	Outdoor air economizer cycle		✓	✓
	Minimize reheat and simultaneous heating and cooling		✓	✓
	No-leak-by control valves for hydronic heating systems		✓	✓
	Computer room cooling from separate equipment		✓	✓
	Heat recovery for outside air from exhaust		✓	✓
	Clean A/C condenser and evaporator coil fins annually	✓		
	Use high quality filters; replace often to keep coils clean	✓		
	Central Cooling	Chiller efficiency 0.5 kW/ton or better		✓
Lock out below 55 degrees if buildings have air-side economizer		✓	✓	✓
Variable speed pumping			✓	✓
Up-size cooling towers to reduce central chiller kW			✓	✓
Evaporative pre-cooling for air-cooled chillers			✓	✓
Clean condenser tubes annually		✓		
Central Heating	Lock out above 60 degrees	✓	✓	✓
	Air/Water economizers for boilers		✓	✓
	Reduce excess air		✓	✓
	Hot water reset from outside air temperature	✓	✓	✓
	Modular boilers for reduced standby losses		✓	✓
	Separate space heating and domestic water heating equipment		✓	✓

This list is considered representative of typical segment business use, but is not all inclusive and does not replace a formal energy audit. Energy savings are not guaranteed. For additional information, contact Colorado Springs Utilities at 448-4800 or your Account Manager. This information is provided in good faith, for use by the customer in conjunction with a qualified engineer or contractor.